

WATER METER DEPARTMENT
 EAST MAIN STREET
 NEWARK, OHIO

METER DEPT: 349-6775
 WATER OFFICE: 349-6730

REMOTE REGISTER TO BE 4'-5'
 ABOVE GROUND ON THE FRONT OR
 ON THE SIDE NEAR THE FRONT.
 NOT PERMITTED ON THE REAR.

WIRE ENCASED IN WEATHER-PROOF
 CONDUIT(WHERE IT IS INACCESSIBLE).
 WIRE TO BE FURNISHED BY THE
 DIVISION OF WATER. (NO SPLICING PERMITTED).

STANDARD WALL CLAMPS
 INSTALLED AT 18" INTERVALS.

*NOTE: WHEN THE WIRE IS CONSIDERED
 INACCESSIBLE FOR REPLACEMENT,
 THE WIRE IS TO BE ENCASED IN
 WEATHER PROOF CONDUIT.
 COMPLETE WATER METER/EXTERIOR
 REGISTER INSTALLATION TO BE
 INSPECTED AND APPROVED BY THE
 CITY OF NEWARK, DIVISION OF WATER.

DIMENSIONAL DESIGN FOR
 METERS AND CONNECTIONS.

METER		COUPLING TAILPIECE (SPUDS)	
SIZE	LENGTH	LENGTH	THREAD
5/8X3/4"	7 1/2"	2 1/2"	3/4"
F-3/4"	9"	2 1/2"	3/4"
1"	10 3/4"	2 5/8"	1"

FOR SIZES 1 1/2" OR LARGER
 REF. #800-WS-5

