

NOTE: ALL MANHOLES SHALL BE CONSTRUCTED TO THE ELEVATION OF THE PROPOSED STREET GRADE OR TO THE PRESENT GROUND ELEVATION, WHICHEVER IS HIGHER, UNLESS OTHERWISE ORDERED.

MANHOLE BARREL SECTIONS CAN BE MADE IN 16",32",48"& 64" LAYING LENGTHS TO SUIT FIELD CONDITIONS. THESE SECTIONS SHALL BE USED IN SUCH COMBINATIONS AS WILL BE NECESSARY TO FIT EACH LOCATION.

MANHOLE STEPS TO BE NEENAH CAST IRON CAT. NO. R-1980-E OR FORGED ALUMINUM ALLOY PER ASTM B221 OR REINFORCED PROPYLENE PLASTIC, PER 711.31 ALL MEETING MINIMUM O.S.H.A. REQUIREMENTS.

CITY OF NEWARK, OHIO DIVISION OF ENGINEERING PRE-CAST CONCRETE MANHOLES

STANDARD DRAWING 900-0

REVISED 5-96 KELLEY