



FOR MANHOLE DETAILS  
SEE STD. DWG. 900-0  
AND 900-6.

5" CLASS "C"  
CONCRETE  
ENCASEMENT. →

FOR CONCRETE REQUIREMENTS  
SEE ITEM NO. 499 OF O.D.O.T.  
CONSTRUCTION AND MATERIAL  
SPECIFICATIONS.

A DROP MANHOLE IS TO BE USED WHENEVER THE SEWER  
ENTERING THE MANHOLE IS 2' OR MORE ABOVE THE  
MANHOLE INVERT.

CITY OF NEWARK, OHIO  
DIVISION OF ENGINEERING

STANDARD DRAWING 900-2

DROP MANHOLE

7-81  
PIPES

REVISED