



FOR TRENCH
DETAILS SEE
STD. DWG.
900-5.

THIS DRAWING PERTAINS ONLY TO NEW SEWER CONSTRUCTION.

THE INVERT AT THE END OF THE LATERAL SHALL BE A MINIMUM OF 9.0 FT. BELOW EXISTING STREET C/L ELEVATION FOR VACANT LOTS.
 THE INVERT AT THE END OF THE LATERAL SHALL BE A MINIMUM OF 10.0 FT. BELOW FINISH FLOOR ELEVATION ON ALL EXISTING HOUSES.
 LATERAL TO BE BEDDED IN MIN. OF 6" OF NO. 57 WASHED GRAVEL TO A DEPTH OF 12" OVER THE TOP OF THE PIPE.

CITY OF NEWARK, OHIO
 DIVISION OF ENGINEERING

STANDARD DRAWING 900-4
 HOUSE SEWER LATERALS

8-91
 PIPES
 REVISED
 5-86 KELLEY
 11-00 KELLEY