



THIS DRAWING PERTAINS ONLY TO SEWER DISCONNECTION

CAPPED LATERAL TO BE BEDDED IN MIN. OF 6" OF NO. 57 WASHED GRAVEL TO A DEPTH OF 12" OVER THE TOP OF THE PIPE.

01-2001
KELLEY
REVISED

CITY OF NEWARK, OHIO DIVISION OF ENGINEERING	STANDARD DRAWING 900-4A	SEWER LATERAL DISCONNECT
	SEWER LATERAL DISCONNECT	