

**Rule 14 - ACCEPTABLE WATER METER SIZES**

- A. Single residential dwellings - - - 5/8" x 3/4"
- B. Apartment buildings - - - each building having two or more living units.

<u>Number of Apartments</u>		<u>Sizes</u>
2	Units	Full 3/4"
3--11	Inclusive	1"
12--19	Inclusive	1-1/2"
20--49	Inclusive	2"
50--99	Inclusive	3"
100-200	Inclusive	4"
200-plus	Inclusive	6"

Multi-building complexes on a single tap may have the tap sized by the total of the apartments serviced by the tap.

Add one apartment unit for each four washers installed for central laundry use at apartments.

- C. Commercial and industrial buildings:

Fire insurance requirements and user requirements will rule in these cases.  
(Must be authorized by Utilities Superintendent)


**Additional Information:**

**Whenever there is more than two meters on a service line the following is required:**


<b>One to two meters</b>	<b>3/4 " water service</b>
<b>Three to four meters</b>	<b>1" water service</b>
<b>Five to six meters</b>	<b>1 1/4" water service</b>
<b>Seven to eight meters</b>	<b>1 1/2" water service</b>
<b>Nine or more</b>	<b>2" water service</b>

**The Newark City Health Department will only issue plumbing permits to registered plumbing contractors and homeowners that are doing their own work in their place of residence.**

Approved:



David Rhodes, Director of Public Service



Date