

Rule 8 - PRIVATE STOPS/LOCKSTOPS - MULTIPLE WATER METERS

Whenever an additional meter is requested where one or more meters already exist, the property owner will be required to install private stops outside the structure according to drawing 800-WS-3A (see Rule 14 for sizing). An onsite inspection is required by a Division of Water and Wastewater employee to approve line size, as listed in Rule 14, approve meter location and approve general metering requirements. All meter settings require a shutoff valve before the meter, a meter, an approved backflow preventer, and a second valve. Lockstops will only be permitted in very limited situations and these shall be determined by a Water Department Supervisor. Replacement, maintenance and repair of private lines and/or stops shall be in accordance with the Division of Water and Wastewater specifications with the cost borne by the customer.

All line sizing shall conform to accepted engineering practice and as listed in Rule 14.

Approved:



David Rhodes, Director of Public Service

7/22/15

Date